



TAMILNADU POLLUTION CONTROL BOARD

District Environmental Laboratory, Ambattur.

Report of Analysis

ROA No: 3256/2025-2026

Dated : 01.04.2026

1. Nature and No. of Sample(s) : One Number of Sample
2. Date of Collection : 20.03.2026
3. Sample Code No. and Point of Collection : DEEGMP 251540 - STP Outlet - Treated

Sl. No.	Parameters	DEE Code	DEEGMP 251540
		Lab Code	3256
		Unit	1
1	pH		7.36
2	Total Suspended Solids	mg/l	10
3	B O D at 27°C for 3 Days	mg/l	3
4	C O D	mg/l	24
5	Total Nitrogen (NO ₃ +NO ₂)	mg/l	<1
6	Ammoniacal Nitrogen	mg/l	<2
7	Fecal Coliform	MPN/ 100ml	FNA

'FNA' - Facility not Available;

Sample collection charges Rs.1050 /-
(Rupees One Thousand and Fifty Only)

Analytical charges Rs.4250 /-
(Rupees Four Thousand Two Hundred and Fifty Only)


Deputy Chief Scientific Officer
DEL, Ambattur.


1/4